



...Dedicated to Community Service

2554 SWEETWATER SPRINGS BOULEVARD, SPRING VALLEY, CALIFORNIA 91978-2098
TELEPHONE: 670-2222 AREA CODE 619

March 5, 2001

W.O. 8494

Mr. Christopher H. Norton
Latham & Watkins Law Firm
650 Towne Center Drive, 20th Floor
Costa Mesa, CA 92626-1925

Subject: Larkspur Energy Facility- Project Wildflower, APN: 646-130-48

Mr. Norton:

The Otay Water District (OWD) has emergency storage capacity to serve the above referenced project. The project is bordered on the north by an OWD 24" water main in Otay Mesa Road, and on the west by an OWD 16" water main in Harvest Road.

The Otay Water District has no objection to this project. The Developer may be required to submit improvement plans for approval. If service laterals do not exist for the project, the applicant must pay to have the District install them, and each service must have an approved R/P Backflow Device, purchased and installed by the owner. All fees including meter fees will have to be paid prior to any services being provided.

Irrigation plans must be designed to reclaim standards and specifications and submitted to the District and the Department of Environmental Health (DEH), for plan check and approval, prior to the purchase of any irrigation meter(s).

The applicant should contact the projects fire agency, for any fire protection requirements. The Otay Water District should then be contacted at (619) 670-2241, regarding service laterals, Backflow Devices, and/or meter costs. If you have any questions, please feel free to give the office a call. Thank you.

Sincerely,
OTAY WATER DISTRICT

David T. Charles
Engineering Public Services Supervisor

DTC:mf